

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No: 7270-0074:104

Page 1 of 1

CATEGORY: Heat Detector

LISTEE: Fenwal, 400 Main Street, Ashland MA 01721
Contact: Terrill Garland (508) 881-2000

DESIGN: Models 27020-0, 27020-1, *27021-0, *27021-1, 27120-0, 27121-0, 27121-20, 28021-0, 28021-5, 28020-3, and 27120-22 rate compensation type heat detectors. All models are suitable for releasing device service except Models 27021-0, 27021-1, 27121-0, 27121-20, 28021-0 and 28021-5. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: Rated 100 - 559°F

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model designation, classification and UL label.

APPROVAL: Listed as heat detectors for use with separately listed compatible bases and fire alarm control units.

NOTE: Combined with 7270-0074:001

*Corrected 05-30-96



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 8, 2002**

*Listing Expires **June 30, 2003***

Authorized By: **DIANE K. AREND, Senior Deputy
Program Manager**